

CODE NUMBER

3918274

DESCRIPTION

1.28 gpf, Dual-Filtered Bypass, Rough Brass Finish, 1.5" Flush Connection, Fixture Connection Rear Spud, Single Flush, 1" Inlet, 1", Wheel Handle Control Stop, 9.75 L Dimension, Royal® Concealed Manual Specialty Water Closet PWT Flushometer.

DETAILS

Flush Volume: 1.28 gpf (4.8 Lpf)Finish: Rough Brass (RB)

· Valve: Diaphragm

Bypass: Dual-Filtered Bypass (DBP)Valve Body Material: Semi-red Brass

Fixture Type: Water Closet
Fixture Connection: Rear Spud
Rough-In Dimension: 16" (406mm)

Spud Coupling: 1 ½" (38mm)Supply Pipe: 1" (25mm)

L Dimension: 9 ¾" (248mm) (9-3/4-LDIM)
Control Stop: 1", Wheel Handle (1-IN-STOP-K)

• Inlet: 1" ()

• Flush Connection: 1.5" (T)

FEATURES

- 2954-953-000
- PERMEX synthetic rubber diaphragm with Dual Filtered Fixed Bypass
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037.



COMPLIANCES & CERTIFICATIONS





(BAA Compliant, cUPC Certified)

RECOMMENDED SPECIFICATION

Valve Body, Cover, Tailpiece and Control Stop shall be in conformance with ASTM Alloy Classification for Semi- Red Brass. Valve shall be in compliance with the applicable sections of ASSE 1037 and ANSI/ASME 112.19.2.

VALVE OPERATING PRESSURE (FLOWING)

15–80 PSI (103–552 kPa). Specific fixtures may require greater minimum flowing pressure - consult manufacturer requirements.

DOWNLOADS

- Concealed Flushometer Installation Instructions for Stainless Steel Fixtures
- Control Stop Repair and Maintenance Guide
- Flush Connections Flanges Repair and Maintenance Guide
- Tail Piece Repair and Maintenance Guide
- Royal Manual Diaphragm Flushometer Repair and Maintenance Guide
- Concealed Flushometers Repair and Maintenance Guide
- Additional Downloads

NOTES

All information contained within this document subject to change without notice.

Looking for other variations of the ROYAL 603 product? View the general spec sheet with all options.



ROUGH-IN

